SP2 THERMAL FLOW SWITCH OPERATION MANUAL

1.Introduction

Thermal dispersion flow switch is a precise flow sensing device, whose movement principle is heat diffusion. The probe consists of two temperature sensors. One sensor measures the temperature of the fluid when the probe is immersed. The other sensor is heated by a constant power.



This creates a temperature difference between two sensors. Temperature difference a proportional to the flow velocity. The probe and housing are made by stainless steel or engineering plastic. Since the device is without moving parts, therefore there is no wear and tear problem.and sensitivity individually. User can set the alarm and sensitivity easily.

2.Mounting instruction

When installing SP, please use supplied sealing ring.(Not including NPT&PT fitting).

- (1).Please assure the minimum distance to the tube bends and intersections greater than four times of pipe diameter. (See Fig. 1)
- (2).Please assure that there is no air bubble in the tube to achieve reliable alarm action. (See Fig. 2).
- (3).When the fluid does not completely fill the pipe, SP must be installed below the pipe. And the fluid level must be higher than the tip of the SP.(See Fig. 3)
- (4).Must secure the mounting is firmly locked to avoid the danger of liquid leakage from the pipe. To ensure the optimal sensitivity and response time, it should be installed in the direction as shown in Figure 4
- (5).If there are any particle exists in the fluid, please install a suitable filtering element at the upstream of SP to prevent contamination on the probe of SP.





Fig. 2



Fig. 3

Fig. 1





) (E 🕅

3.Flow monitoring

- SP is equipped with 6 LEDs for visual flow velocity monitoring. (See Fig.5)
- (1). Red LED : Flow velocity is below alarm setting. Output == [OFF]
- (2). Yellow LED: Flow velocity is close to alarm setting. Output == [ON]
- (3). Green LEDs(×4): Degree of the flow velocity over the alarm setting. Output == [ON]

4.Alarm setting

- (1). Installing the SP on the flow piping.
- (2). Power ON SP and wait for at least 15 seconds for initial warm up.
- (3). a. For open collector output type : Removing two screws of sensitivity and alarm. (See Fig.5)b. For relay output type : Removing the cover
- (4). Adjust the sensitivity setting counter-clockwise to minimum.
- (5). Adjusting the flow velocity to the minimum acceptable level.
- (6). Adjust the alarm setting until yellow LED and three green LEDs lit .



(7). Slowly adjust alarm setting clockwise until yellow LED and one green LED lit.



(8). Slowly decreasing the flow velocity until red LED lit to check the flow velocity of alarm engaged.

- (9). If the velocity deviation between yellow and red LEDs is too large, then adjust the sensitivity setting clockwise to increase sensitivity. Do step (5),(6),(7) again.
- (10). a. For open collector output type : Putting two screws of sensitivity and alarm back.b. For relay output type : Putting the cover back

5.Specification

- (1). Flow velocity: 1~150 cm/s (water), 3~300 cm/s(oil)
- (2). Switching point: Flow velocity ≤50cm/s @25°C,Water
- (3). Warm-up time: 15 sec. (approximate)
- (4). Operation temperature: -20 ~ 80°C(fluid), (SP202: 120°C max.)
- (5). Operation pressure: 100 bar (max.)
- (6). Degree of protection: IP67
- (7). Supply voltage: 19~30Vdc
- (8). Output: Open collector---NPN / PNP, 400 mA max. (with current limiting).
 - Relay---1A/30Vdc, 0.3A/125Vac (NO or NC), 5A/250Vac max. (SPDT)

Fig. 4

Fig.5

6.Wiring

3-wire



Fig. 6, NPN output type wiring



Fig. 7, PNP output type wiring



Fig. 8, 5A Relay output type wiring

7.Pin assignment



Fig. 12 Terminal diagram (NPN & PNP and 1A Relay output type)

4-wire



Fig. 9, 1A Relay output type wiring (NO)



Fig. 10, 1A Relay output type wiring (NC)



5-terminal

Fig. 11, 5A Relay output type wiring





9.Maintenance

Under normal operating conditions, no special maintenance is required. Contamination on the probe of SP could change its thermal property. If necessary, using a suitable solvent to clean the surface of the probe periodically.

After cleaning process, re-checking alarm setting and leakage of sealing ring is recommended.

10.Warranty

The warranty of SP is described as following:

Period of warranty: 12 months after receiving.

Validation of warranty: The warranty is valid only when the SP is using under normal operating condition specified in the specifications of SP.

Our warranty: Replace with new SP or repairing.

*Subject to change without notice **%**Screw table

Standard						
Screw	PF,BSP		PT,NPT			
	Screw head	L	Screw head	L		
1/4"	8.5mm	25mm	10mm	25mm		
1/2"	10.5mm	31mm	19mm	40mm		
1"	16mm	36mm	20mm	40mm		

Extension							
Screw	PF,BSP		PT,NPT				
	Screw head		Screw head				
1/2"	11.5mm	16mm	16mm	20mm			
1"	16mm		20mm				





FineTek Co., Ltd. No.16, Tzuchiang St., Tucheng Industrial Park, New Taipei City 23678, Taiwan Tel: 886-2-22696789 Fax: 886-2-22686682 Email: info@fine-tek.com http://www.fine-tek.com



08-SP2XX-B4-EM,05/05/2023

ISO 9001